

AMETEK®

Pulsar® Model R96 Pulse Burst Radar Level Transmitter

DESCRIPTION

The Pulsar® R96 Radar transmitter is the latest generation of Magnetrol® 24 V DC, loop-powered, non-contact radar transmitters. Enhanced performance and innovative diagnostics bring simplicity to an often complicated technology.

This latest entry into the radar level measurement field is designed to provide unparalleled performance and ease of use. PULSAR non-contact radar is the perfect compliment to the MAGNETROL Eclipse® Model 706 Guided Wave Radar transmitter. Together, these transmitters offer the ultimate solution to the vast majority of process level applications.

TECHNOLOGY

The PULSAR Radar transmitter is based on pulse burst radar technology combined with equivalent time sampling circuitry. Short bursts of 6 GHz microwave energy are emitted and subsequently reflected from the liquid level surface. Distance is calculated by the equation $\mathbf{D} = \mathbf{Transit}$ time (round-trip)/2. Liquid level is then calculated by applying the tank height value.

APPLICATIONS

MEDIA: Liquids and slurries; hydrocarbons to water-based media (dielectric 1.7–100)

VESSELS: Most metal and concrete process or storage vessels up to rated temperature and pressure. Pits and sumps as well as glass-lined tanks.

CONDITIONS: Virtually all level measurement and control applications including process conditions exhibiting varying specific gravity and dielectric, visible vapors, high fill/empty rates, turbulence, low to moderate foam and buildup.



- Multivariable two-wire, 24 VDC loop-powered transmitter for level or volume
- Performance not process dependent (changing specific gravity and dielectric have no effect)
- 6 GHz operating frequency offers superior performance in the tougher applications with turbulence, foam, and heavy vapors
- Echo Rejection setup is simple, intuitive and effective
- Antenna designs to +200 °C (+400 °F),
 -1.0 to 51.7 bar (-14.7 to 750 psig)
- Range up to 40 m (130 ft)
- Quick connect/disconnect antenna coupling allows vessel to remain sealed
- Extremely low output at antenna: < .01 mW (avg),
 2 mW (max); hundreds of times less than a cell phone
- 4-button keypad and graphic LCD display allow for convenient viewing of configuration parameters and echo curve
- Proactive diagnostics advise not only what is wrong, but also offer troubleshooting tips
- Available for use in SIL 2 Loops (92.7 % SFF, with full FMEDA report available)
- PACTware[™] PC Program and enhanced DTMs for advanced configuration and troubleshooting
- Available with HART® or FOUNDATION Fieldbus™ digital output

PULSE BURST RADAR

PULSAR R96 is a top-mounted, downward-looking pulse burst radar operating at 6 GHz. Unlike true pulse devices (e.g. ECLIPSE Guided Wave Radar) which transmit a single, sharp (fast rise-time) waveform of wide-band energy (Figure 1), PULSAR emits short bursts of 6 GHz energy (Figure 2) and measures the transit time of the signal reflected off the liquid surface.

Distance is calculated utilizing the equation Distance equals the Speed of light multiplied by the transit time divided by two (*Distance* = $C \times Transit\ Time/2$), then developing the level value by factoring in tank height and other configuration information (Figure 3). The exact reference point for distance and level calculations is the sensor reference point (bottom of an NPT thread, top of a BSP thread, or face of a flange).

The exact level measurement is extracted from false target reflections and other background noise via the use of sophisticated signal processing. The new PULSAR Model R96 circuitry is extremely energy efficient so no duty cycling is necessary to accomplish effective measurement.




Figure 1




Figure 2




Figure 3


OPERATIONAL CONSIDERATIONS

Radar applications are characterized by three basic conditions:

- Dielectric (process medium)
- Distance (measuring range)
- Disturbances (turbulence, foam, false targets, multiple reflections and rate of change)

The PULSAR R96 Radar transmitter is offered with four antenna configurations:

- Polypropylene Dielectric Rod
- TFE Dielectric Rod
- 4" Horn
- 6" Horn



Distance = Sensor Level Distance - Level Trim

Maximum measuring range (distance) is measured from the sensor reference point (bottom of NPT thread, top of BSP thread, or face of flange) to the bottom of the tank. Refer to Figure 4.

Ideally, the 6" horn antenna should be used to ensure the best possible performance in all operational conditions. However, since that is impractical in most cases, other antennas are available. The chart shows the maximum measuring range of each antenna based on dielectric and turbulence. Refer to Figure 5.

Obstructions, noise and media buildup drastically decrease reliable measurement. Although it is theoretically possible to measure a liquid level on the antenna, liquid should not be allowed closer than 50 mm (2") from the bottom of the antenna due to the decrease in accuracy when liquid level is present on the antenna. Refer to Figure 6.

Figure 4

| R96 Maximum Recommended Measuring Range in m (ft) | | | | | | |
|---|-----------------------------|---------|-------------------------------|--------|----------|---------|
| | Turbulence None or Light | | Turbulence Medium or Heavy | | | |
| Dielectric > | 1.7 - 3 3 - 10 10 - 100 | | 1.7 - 3 | 3 - 10 | 10 - 100 | |
| Antenna Type | | | | | | |
| Dielectric Rod | 5 (16) 12 (39) | 20 (66) | 2 (10) | 0 (00) | 10 (20) | |
| 4" Horn | 5 (16) | 12 (39) | 20 (00) | 3 (10) | 9 (29) | 12 (39) |
| 6" Horn | 10 (33) | 25 (82) | 40 (131) | 5 (16) | 12 (39) | 16 (52) |

Figure 5




Figure 6

The PULSAR Model R96 Radar transmitter can be mounted on a vessel using a variety of process connections. Generally either a threaded or flanged connection is used.

LOCATION

Ideally, the Radar transmitter should be mounted 1/2 radius from center of the tank providing an unobstructed signal path to the liquid surface where it should illuminate (with microwave energy) the largest possible surface area. Do not install in center of tank top or within 45 cm (18") of tank wall. Tank walls may produce reflections that must be minimized during field configuration (Antenna Orientation). Refer to Figure 7.

BEAM ANGLE


The various antenna designs exhibit different beam patterns. Figure 9 shows the beam spread for all PULSAR antennas. Ideally the beam pattern should illuminate the maximum liquid surface with a minimum striking other objects in the vessel including the tank wall. Use these drawings to determine the optimum installation location.

O B S T R U C T I O N S

Almost any object that falls within the beam pattern will cause reflections that may be misinterpreted as a false liquid level. Although the PULSAR Model R96 has a powerful Echo Rejection routine, all possible precautions should be taken to minimize false target reflections with proper installation and orientation. Refer to Figures 8 & 9.

| Antenna | Beam S | B; m (ft) | |
|----------------|----------------|----------------|----------------|
| Beam Angle (∝) | Dielectric Rod | 4" Horn 25° | 6" Horn 17° |
| Distance, D | 20 | 20 | ., |
| 3 (10) | 1,4 | (4.5) | 1,0 (3.0) |
| 6 (20) | 2,7 (8.9) | | 1,8 (6.0) |
| 9 (30) | 4,11 (3.3) | | 2,7 (9.0) |
| 12 (40) | 5,4 (17.8) | | 3,7 (12.0) |
| 15 (50) | 6,8 (22.2) | | 4,6 (15.0) |
| 18 (60) | 8,1 (26.6) | | 5,5 (18.0) |
| 20 (65) | 8,8 (28.9) | | 6,0 (19.5) |
| 30 (98) | * | | 9,0 (29.3) |
| 40 (130) | * | | 12,0 (39.0) |

^{*}Dielectric rod and 4" horn not recommended beyond 20 m (65 ft)








Figure 8



NOZZLES

Improper installation in a nozzle creates "ringing" (undesired signals) which will adversely affect measurement. The antenna should always be mounted so the active section of the antenna is a minimum of 13 mm (0.5") below the nozzle. Be sure to include any nozzle dimension *inside* the vessel. Refer to Figure 10. Antenna extensions are offered to allow the PULSAR Model R96 transmitter to work reliably in nozzles with "L" dimensions of 25 mm (1"), 100 mm (4"), 200 mm (8") or 300 mm (12"). Standard antennas are shown below for reference.








Figure 10



| DIELECTRIC R | RODS - mm | (inches) |
|---------------------|-----------|----------|
|---------------------|-----------|----------|

| Model # | Antenna Extension | All | All | BSP |
|-----------|----------------------------|------------|------------|------------|
| 8th Digit | (maximum "L" dimension) | Dim A | Dim B | Dim C |
| 0 | 25 (1) | 58 (2.3) | 282 (11.1) | 76 (3.0) |
| 1 | 100 (4) | 160 (6.3) | 389 (15.3) | 185 (7.3) |
| 2 | 200 (8) | 267 (10.5) | 493 (19.4) | 287 (11.3) |
| 3 | 300 (12) | 368 (14.5) | 594 (23.4) | 389 (15.3) |

| Antenna Extension O.D. Dimension D | | | |
|-------------------------------------|-------------|--|--|
| TFE Rod | Ø 38 (1.50) | | |
| PP Rod | Ø 38 (1.50) | | |




HORNS - mm (inches)

| HONNS - IIIII (IIICIIes) | | | | |
|--------------------------|--------------------------------|------------|------------|--|
| Model # | Antenna Extension (maximum "L" | 4" Horn | 6" Horn | |
| 8th Digit | dimension) | Dim H | Dim H | |
| 1 | 100 (4) | 117 (4.6) | 1 | |
| 2 | 200 (8) | 213 (8.4) | 211 (8.3) | |
| 3 | 300 (12) | 315 (12.4) | 315 (12.4) | |
| Aperture | | 95 (3.75) | 146 (5.75) | |

STANDPIPES AND STILLWELLS

The PULSAR Model R96 can be mounted in a standpipe or still-well but certain items must be considered:

- Metal stillwells only: Sizes 4–8 inches (100–200 mm).
- Diameter must be consistent throughout length; no reducers.
- Use only horn antennas sized to pipe ID; 4–6" (100–150 mm); 8" pipe can use a 6" horn.
- Stillwell length must cover complete range of measurement (i.e., liquid must be in stillwell).
- Welds should be smooth.
- Vents: holes < 13 mm (0.5") diameter, slots < 13 mm (0.5") width.
- If an isolation valve is used, it must be a full port ball valve with an I.D. equal to the pipe diameter.
- Bridles/Bypass Installations: The launcher (index mark) should be rotated 90° from process connections.
- Configuration must include a non-zero entry for PIPE I.D.
- There will be some increased dielectric sensitivity;
 system GAIN will be reduced when PIPE ID > 0.
- There will be a slight reduction in Maximum Range based on the table at right.



Maximum Range

| PIPE I.D. | | Propagation | Maximu | m Range |
|-----------|-----|--------------|--------|---------|
| inch | mm | Speed Factor | feet | meters |
| 4 | 100 | 0.955 | 62.7 | 19.1 |
| 6 | 150 | 0.98 | 64.3 | 19.6 |
| 8 | 200 | 0.99 | 65.0 | 19.8 |

Figure 11

MOUNTING

ORIENTATION

The PULSAR Model R96 transmitter utilizes a linearly polarized, microwave beam that can be rotated to improve its performance. Proper orientation can minimize unwanted target reflections, decrease sidewall reflections (multipath) and maximize direct reflections from the liquid surface. The index mark located on the side of the launcher is oriented in the same direction as the polarization. 45° is initially recommended. Refer to Figure 12.

The index mark is also present for reference (1 dot: GP/IS or 2 dots: XP). The launcher is considered to be at 0° when the index mark is closest to the tank wall.





Figure 12

PULSE BURST RADAR

STORAGE AND INTERMEDIATE HOLDING TANKS

CONDITIONS - Calm Surfaces






REACTORS

CONDITIONS – Turbulence and Foam



ENCLOSED SUMPS


CONDITIONS - Turbulence, Foam, and Changing Dielectric



PULSE BURST RADAR

MIXERS AND BLENDING VESSELS

CONDITIONS - Turbulence, Foam, and Changing Dielectric



CHAMBERS AND BYPASS



PROBLEMATIC APPLICATIONS

GUIDED WAVE RADAR ALTERNATIVE

Some applications can be problematic for Non-Contact Radar. The following are examples of when Guided Wave Radar is recommended.

- Extremely low dielectric media (ε_r <1.7)
- Very weak reflections from the liquid surface (particularly during turbulence) can cause poor performance.
- Tanks heavily cluttered with false targets (mixers, pumps, ladders, pipes, etc.)
- During times of very low liquid levels of low dielectric media, the metal tank bottom may be detected, which can deteriorate performance.
- Foam can either absorb or reflect the microwave energy depending upon the depth, dielectric, density and wall thickness of the bubbles. Due to typical variations in the amount (depth) of foam, it is impossible to quantify performance. It may be possible to receive most, some or none of the transmitted energy.
- Extremely high liquid level (Overflow) conditions when liquid very near the antenna can cause erroneous readings and measurement failure.

Refer to ECLIPSE Model 706 Guided Wave Radar bulletin BE57-106.









These units are in compliance with the RED-directive 2014/53/EU, the PED-directive 2014/68/EU and the ATEX directive 2014/34/EU.

Explosion Proof

US/Canada:

Class I, Div 1, Group B, C, D, T4 Class I, Zone 1 A Ex db ia IIB + H2 T4 Class I, Zone 1 Ex d ia IIB + H2 T4 Ta = -40 °C to +70 °C Type 4X, IP67

Flame Proof

ATEX - FM14ATEX0058X

II 1/2 G Ex db ia IIB + H2 T4... T1 Ga/Gb Ta = -40 °C to +70 °C IP67

IEC- IECEx FMG 15.0034X

Ex db ia IIB + H2 T4...T1 Ga/Gb Ta = -40 °C to +70 °C IP67

Intrinsically Safe

US/Canada:

Class I, II, III, Div 1, Group A, B, C, D, E, F, G, T4 Class I, Zone 0 AEx ia IIC T4 Class I, Zone 0 Ex ia IIC T4 Ga Ta =-40 $^{\circ}$ C to + 70 $^{\circ}$ C Type 4X, IP67

ATEX - FM14ATEX0058X:

II 1 G Ex ia IIC T4 Ga Ta = -40 °C to +70 °C IP67

IEC - IECEx FMG 15.0034X:

Ex ia IIC T4 Ga Ta = -40 $^{\circ}$ C to +70 $^{\circ}$ C IP67

Non-Incendive

US/Canada:

Class I, II, III, Div 2, Group A, B, C, D, E, F, G, T4 Class I, Zone 2 AEx nA ia IIC T4 Class I, Zone 2 Ex nA ia IIC T4 Ta = -40 °C to +70 °C Type 4X, IP67

Non-Sparking

ATEX - FM14ATEX0059XII 3 G Ex nA IIC T4 Gc
Ta = -15 °C to +70 °C
IP67

IEC - IECEx FMG 15.0034X

Ex nA IIC T4 Gc Ta = -15 °C to + 70 °C IP67

FM3600:2011, FM3610:2010, FM3611:2004, FM3615:2006, FM3616:2011, FM3810:2005, ANSI/ISA60079-0:2013, ANSI/ISA 60079-1:2015, ANSI/ISA 60079-1:2013, ANSI/ISA 60079-15:2012, ANSI/ISA 60079-26:2011, NEMA 250:2003, ANSI/IEC 60529:2004, C22.2 No. 0.4:2009, C22.2 No. 0.5:2008, C22.2 No. 30:2007, C22.2 No. 94:2001, C22.2 No. 213:2012, C22.2 No. 1010.1:2009, CAN/CSA 60079-0:2011, CAN/CSA 60079-1:2011, CAN/CSA 60079-1:2011, CAN/CSA 60079-1:2014, EN60079-1:2012, EN60079-1:2012, EN60079-1:2014, EN60079-1:2014, EN60079-1:2014, EN60079-1:2011, IEC60079-1:2010, IEC60079-26:2006, IEC60079-31:2008

"This equipment with chargeable non-conductive parts, e.g. enclosure's paint and antenna use PTFE, Co-polymer Polypropylene or Noryl En265, is provided with a warning label referring to the safety measures that must be taken if there is electrostatic charging during operation. For use in hazardous area, the equipment and side to be installed, e.g. tank, must be connected to earth and be attention to not only the measuring object, e.g. liquids, gases, powders and etc., but also the related conditions, e.g. tank container, vessel and etc. (According to IEC 60079- 32-1)."

FCC (ID# LPN-R9C) Compliance Statement:

This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications.

Telecommunications Approvals

| Agency | In-Tank | Out of Tank | |
|--------|--|--|--|
| FCC | 47 CFR, Part 15, Subpart C,Section 15.209 Unintentional Radiators | 47 CFR, Part 15, Subpart C, Section 15.256 | |
| ISED | RSS-211 | RSS-211 | |

TRANSMITTER SPECIFICATIONS

FUNCTIONAL/PHYSICAL

| Measurement Principle | | Pulse burst radar 6 GHz |
|-----------------------------|------------------|--|
| Input | | |
| Measured Variable | | Level, determined by the time-of-flight of radar pulse reflections |
| Span | | 0,2 to 40 m (0.5 to 130 ft) |
| Output | | |
| Туре | | 4 to 20 mA with HART: 3.8 mA to 20.5 mA useable (per NAMUR NE43) |
| | | Foundation Fieldbus™: H1 (ITK Ver. 6.1.2) |
| Resolution | Analog: | .003 mA |
| 1 | Digital Display: | 1 mm |
| Loop Resistance | | 591 ohms @ 24 V DC and 22 mA |
| Diagnostic Alarm | | Selectable: 3.6 mA, 22 mA (meets requirements of NAMUR NE 43), or |
| | | HOLD last output |
| Diagnostic Indication | | Meets requirements of NAMUR NE107 |
| Damping | | Adjustable 0-10 |
| User Interface | | |
| Keypad | | 4-button menu-driven data entry |
| Display | | Graphic Liquid Crystal Display |
| Digital Communication | | HART Version 7-with Field Communicator, FOUNDATION Fieldbus™ AMS, or FDT |
| | | DTM (PACTware™), EDDL |
| Menu Languages Tra | ansmitter LCD: | English, French, German, Spanish, Russian |
| | HART DD: | English, French, German, Spanish, Russian, Chinese, Portuguese |
| FOUNDATION Fieldbus" | Host System: | English |
| Power (Measured at instrume | nt terminals) | HART: General Purpose (Weather proof)/Intrinsically Safe/Explosion-proof: |
| | | 11 V DC minimum under certain conditions (refer to I/O Manual BE58-602) |
| | | Foundation Fieldbus™: 9 to 17.5 V DC |
| | | FISCO, FNICO, Explosion Proof, General Purpose and Weather Proof |
| Housing | | |
| Material | | IP67/die-cast aluminum A413 (<0.6 % copper); optional stainless steel |
| Net/Gross Weight | Aluminum: | 2,0 kg (4.5 lbs.) |
| | Stainless Steel: | 4,50 kg (10.0 lbs.) |
| | | H 212 mm (8.34") × W 102 mm (4.03") × D 192 mm (7.56") |
| Overall Dimensions | | |
| | | 1/2" NPT or M20 |
| Cable Entry | egrity Level) | |
| | egrity Level) | 1/2" NPT or M20 Safe Failure Fraction = 92.7 % (HART only) Functional Safety to SIL 2 as 1001 in accordance with IEC 61508 |

ENVIRONMENT

| Operating Temperature | -40 °C to +80 °C (-40 °F to +175 °F); LCD viewable -20 °C to +70 °C (-5 °F to +160 °F) |
|-------------------------------|--|
| Storage Temperature | -45 °C to +85 °C (-50 °F to +185 °F) |
| Humidity | 0-99 %, non-condensing |
| Electromagnetic Compatibility | Meets CE requirement (EN 61326) and NAMUR NE 21 |
| Surge Protection | Meets CE EN 61326 (1000V) |
| Shock/Vibration | ANSI/ISA-S71.03 Class SA1 (Shock); ANSI/ISA-S71.03 Class VC2 (Vibration) |

PERFORMANCE


| Reference Conditions | Reflection from ideal reflector at +20 °C (+70 °F) |
|-------------------------------------|--|
| Linearity | ± 8 mm (0.3") or 0.1 % of tank height (whichever is greater) |
| Measured Error | \pm 8 mm (0.3") or 0.1 % of tank height (whichever is greater) (Performance will degrade slightly within 1,5 m (60") of antenna) |
| Resolution | 1 mm or 0.1" |
| Repeatability | ± 5 mm (0.2") or 0.05 % of tank height (whichever is greater) |
| Response Time | < 2 seconds (configuration dependent) |
| Initialization Time | < 30 seconds |
| Ambient Temperature Effect Digital: | Horn Antenna: Average 3 mm (0.12") / 10 K, max of \pm 10 mm (0.4") over the entire temperature range -40 °C to +80 °C (-40 °F to +175 °F) |
| | Rod Antenna: Average 0.2 inch (5 mm) / 10 K, max of \pm 15 mm (0.59") over the entire temperature range -40 °C to +80 °C (-40 °F to +175 °F) |
| Analog: | Current Output (additional error with reference to 16 mA span) |
| | Average 0.03 $\%$ / 10 K. max 0.45 $\%$ over entire temperature range -40 $^{\circ}$ C to +80 $^{\circ}$ C (-40 $^{\circ}$ F to +175 $^{\circ}$ F) |
| Maximum Rate of Change | 450 cm (180")/minute |
| Foundation Fieldbus [™] | |
| ITK Version | 6.1.2 |
| H1 Device Class | Link Master (LAS)—selectable ON/OFF |
| H1 Profile Class | 31PS, 32L |
| Function Blocks | (6) Al, (2) Transducer, (1) Resource, (1) Arithmetic, (1) Signal Characterizer, (2) PID, (1) Input Selector |
| Quiescent Current | 17 mA |
| Execution Time | 15 ms (30 ms PID Block) |
| Device Revision | 01 |
| DD Version | 0x01 |
| | |

ANTENNA SPECIFICATIONS

FUNCTIONAL/PHYSICAL

| Model Dielectric Rod TFE | | Dielectric Rod Polypropylene | 4" and 6" Horn |
|---|--|---|---|
| Materials 316 SS (Hastelloy® C opt.), Viton® 0-rings | | 316 SS, Polypropylene, Viton® O-rings | 316 SS (Hastelloy C opt.), Viton® O-rings |
| Process Connection 1 1/2" NPT and BSP, ASME or EN flanges | | 1 1/2" NPT and BSP, ASME or EN flanges | ASME or EN flanges |
| Maximum Process Temperature | +200 °C @ 3.5 bar (+400 °F @ 50 psig) | +95 °C @ 3.5 bar (+200 °F @ 50 psig) | +200 °C @ 3.5 bar (+400 °F @ 50 psig) |
| Maximum Process Pressure -1.0 to 46.5 bar @ +20 °C (-14.7 to 675 psig @ +70 °F | | -1.0 to 51.7 bar @ +20 °C (-14.7 to 750 psig @ +70 °F) | -1.0 to 46.5 bar @ +20 °C (-14.7 to 675 psig @ +70 °F) |
| Minimum Dielectric (application dependent) | 2.0 | 2.0 | 1.7 (1.4 with stillwells) |


TEMPERATURE/PRESSURE CHART




DIMENSIONAL SPECIFICATIONS


MM (INCHES)

TRANSMITTER






ANTENNAS



DIELECTRIC RODS - mm (inches)

| - | 212220111011020 111111 (11101100) | | | | | | | |
|---|-----------------------------------|-------------------------|------------|------------|------------|--|--|--|
| | Model # | Antenna Extension | All | All | BSP | | | |
| | 8th Digit | (maximum "L" dimension) | Dim A | Dim B | Dim C | | | |
| Ī | 0 | 25 (1) | 58 (2.3) | 282 (11.1) | 76 (3.0) | | | |
| Ī | 1 | 100 (4) | 160 (6.3) | 389 (15.3) | 185 (7.3) | | | |
| Ī | 2 | 200 (8) | 267 (10.5) | 493 (19.4) | 287 (11.3) | | | |
| | 3 | 300 (12) | 368 (14.5) | 594 (23.4) | 389 (15.3) | | | |

| Antenna Extension O.D. Dimension D | | | | |
|-------------------------------------|-------------|--|--|--|
| TFE Rod | Ø 38 (1.50) | | | |
| PP Rod | Ø 38 (1.50) | | | |



HORNS - mm (inches)


| | min (menes) | | | |
|----------------------|--------------------------------|------------|------------|--|
| Model # | Antenna Extension (maximum "L" | 4" Horn | 6" Horn | |
| 8th Digit dimension) | | Dim H | Dim H | |
| 1 | 100 (4) | 117 (4.6) | + | |
| 2 | 200 (8) | 213 (8.4) | 211 (8.3) | |
| 3 | 300 (12) | 315 (12.4) | 315 (12.4) | |
| Aperture | | 95 (3.75) | 146 (5.75) | |

O-RING (SEAL) SELECTION CHART

| Material | Code | Maximum Temperature | Maximum Pressure | Min. Temp. | Recommended For Use In | Not Recommended For Use In |
|-------------|------|--|--|--------------------|---------------------------|---|
| Viton® GFLT | 0 | +200 °C @ 16 bar (+400 °F @ 232 psig) | 51.7 bar @ +20 °C (750 psig @ +70 °F) | -40 °C (-40 °F) | General purpose, ethylene | Ketones (MEK, acetone), skydrol fluids, amines, anhydrous ammonia, low molecular weight esters and ethers, hot hydrofluoric or chlorosulfuric acids, sour HCs |

MODEL NUMBER





DIELECTRIC ROD MODEL NUMBER

1 - 2 | TECHNOLOGY / OPERATING FREQUENCY

R A PULSAR radar antennas / 6 GHz

3 | CONFIGURATION / STYLE

| A | TFE |
|---|---|
| В | Polypropylene (Material of Construction codes A and K only) |



| A | 316/316L stainless steel |
|---|---|
| В | Hastelloy C |
| K | 316/316L SS; ASME B31.1 and ASME B31.3 (meets CRN specifications) |

5 - 6 | PROCESS CONNECTION - SIZE/TYPE ①

Threaded

| 31 | 1 1/2" NPT thread |
|----|-----------------------------|
| 32 | 1 1/2" BSP (G 1 1/2) thread |


| ASME Flanges | | | EN Flanges | | | |
|--------------|---------------------------------|----|------------------|-------------------|--|--|
| 43 | 2" 150# ASME raised face flange | DA | DN 50, PN 16 | EN 1092-1 Type A | | |
| 44 | 2" 300# ASME raised face flange | DB | DN 50, PN 25/40 | EN 1092-1 Type A | | |
| 45 | 2" 600# ASME raised face flange | DD | DN 50, PN 63 | EN 1092-1 Type B2 | | |
| 53 | 3" 150# ASME raised face flange | EA | DN 80, PN 16 | EN 1092-1 Type A | | |
| 54 | 3" 300# ASME raised face flange | EB | DN 80, PN 25/40 | EN 1092-1 Type A | | |
| 55 | 3" 600# ASME raised face flange | ED | DN 80, PN 63 | EN 1092-1 Type B2 | | |
| 63 | 4" 150# ASME raised face flange | FA | DN 100, PN 16 | EN 1092-1 Type A | | |
| 64 | 4" 300# ASME raised face flange | FB | DN 100, PN 25/40 | EN 1092-1 Type A | | |
| 65 | 4" 600# ASME raised face flange | FD | DN 100, PN 63 | EN 1092-1 Type B2 | | |
| 73 | 6" 150# ASME raised face flange | GA | DN 150, PN 16 | EN 1092-1 Type A | | |
| 74 | 6" 300# ASME raised face flange | GB | DN 150, PN 25/40 | EN 1092-1 Type A | | |
| 75 | 6" 600# ASME raised face flange | GD | DN 150, PN 63 | EN 1092-1 Type B2 | | |


① Metal flanges welded to antenna; Plastic flanges and metal flanges with threaded antenna connection ordered separately. Refer to Optional Flanges chart on page 15.

7 | O-RINGS


Viton® GFLT

0





HORN MODEL NUMBER



OPTIONAL MOUNTING FLANGES FOR 1 1/2" NPT THREADED VERSIONS - ASME RF (metal) / ASME FF (plastic) (for use with Dielectric Rod Antennas; Extension Codes 1–3 only)

0

0

| Part Number: | 2" | | 3" | | 4" | | 6" | |
|--------------------------|------|------|------|------|------|------|------|------|
| 004-6852 | 150# | 300# | 150# | 300# | 150# | 300# | 150# | 300# |
| 316/316L stainless steel | -001 | -005 | -002 | -006 | -003 | -007 | -004 | -008 |
| 304/304L stainless steel | -009 | -013 | -010 | -014 | -011 | -015 | -012 | -016 |
| Carbon steel | -017 | -021 | -018 | -022 | -019 | -023 | -020 | -024 |
| Hastelloy C | -025 | -029 | -026 | -030 | -027 | -031 | -028 | -032 |
| Monel | -033 | -037 | -034 | -038 | -035 | -039 | -036 | -040 |
| Kynar | -041 | -045 | -042 | -046 | -043 | -047 | -044 | -048 |
| PVC | -049 | -053 | -050 | -054 | -051 | -055 | -052 | -056 |
| Polypropylene | -057 | -061 | -058 | -062 | -059 | -063 | -060 | -064 |
| TFE | -065 | -069 | -066 | -070 | -067 | -071 | -068 | -072 |

R

QUALITY ASSURANCE - ISO 9001

SASTEM CEATIFICATION DNV·GL

THE QUALITY ASSURANCE SYSTEM IN PLACE AT MAGNETROL GUARANTEES THE HIGHEST LEVEL OF QUALITY DURING THE DESIGN, THE CONSTRUCTION AND THE SERVICE OF CONTROLS. OUR QUALITY ASSURANCE SYSTEM IS APPROVED AND CERTIFIED TO ISO 9001 AND OUR TOTAL COMPANY IS COMMITTED TO PRO-

VIDING FULL CUSTOMER SATISFACTION BOTH IN QUALITY PRODUCTS AND QUALITY SERVICE.

PRODUCT WARRANTY

ALL MAGNETROL ELECTRONIC AND ULTRASONIC LEVEL CONTROLS ARE WARRANTED FREE OF DEFECTS IN MATERIALS AND WORK-MANSHIP FOR 18 MONTHS FROM THE DATE OF ORIGINAL FACTORY SHIPMENT. IF RETURNED WITHIN THE WARRANTY PERIOD; AND, UPON FACTORY INSPECTION OF THE CONTROL, THE CAUSE OF THE CLAIM IS DETERMINED TO BE COVERED UNDER THE WARRANTY; THEN, MAGNETROL INTERNATIONAL WILL REPAIR OR REPLACE THE CONTROL AT NO COST TO THE PURCHASER (OR OWNER) OTHER THAN TRANSPORTATION.

MAGNETROL SHALL NOT BE LIABLE FOR MISAPPLICATION, LABOR CLAIMS, DIRECT OR CONSEQUENTIAL DAMAGE OR EXPENSE ARISING FROM THE INSTALLATION OR USE OF THE EQUIPMENT. THERE ARE NO OTHER WARRANTIES EXPRESSED OR IMPLIED, EXCEPT, SPECIAL WRITTEN WARRANTIES COVERING SOME MAGNETROL PRODUCTS.

UNDER RESERVE OF MODIFICATIONS

BULLETIN N°: EFFECTIVE: SUPERSEDES

BE 58-102.2 AUGUST 2021 April 2016

European Headquarters & Manufacturing Facility

Heikensstraat 6 9240 Zele, Belgium

Tel: +32-(0)52-45.11.11

e-mail: info.magnetrolbe@ametek.com

www.magnetrol.com



